


TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087
MONTHLY EFFLUENT REPORT

Page 1 of 3

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865



40B SYS	WQ0010543-011 PERMIT NUMBER	1 SET	0 9 0 4 YEAR MO.	15650 EID
------------	--------------------------------	----------	---------------------------	--------------

THIS REPORT TO BE USED FOR **RECLAIMED WATER TYPE I "800"**

SEE BACK FOR INSTRUCTIONS AND DEFINITIONS

PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
		VALUE					
316164024 FEC. COLI DLY AVG	REPORTED	<1	0	11		03	
	PERMITTED	20.000					
316164030 FEC. COLI IND GRAB	REPORTED	<1	0	11		03	
	PERMITTED	75.000					
500507124 FLOW DLY AVG	REPORTED	0.09	0	02		11	
	PERMITTED						
800821024 BOD CARB DLY AVG	REPORTED	<2	0	11		03	
	PERMITTED	5.000					
820796624 TURBIDITY 30DAYAVG	REPORTED	0.71	0	11		03	
	PERMITTED	3.000					
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0018247	0	01		01	
	PERMITTED						
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	09/11/12	0	01		01	
	PERMITTED						
CLASS OF OPERATOR CERTIFICATE	REPORTED	A	0	01		01	
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						

COMMENTS AND EXPLANATIONS (Reference all attachments here)

Data represents reclaimed water flow from Walnut Creek WWTP TPDES Permit # 10543-011 EPA ID TX0046981.
Walnut Creek WWTP transferred reclaimed water for 18 days.

<small>I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE</small>	NAME	SIGNATURE	DATE
	Mike Welch		0 9 0 5 0 6
TELEPHONE NUMBER	PLANT OPERATOR	PLANT OPERATOR	YEAR MO. DAY
5 1 2 9 7 2 0 1 0 1	Greg Meszaros, Director		0 9 0 5 0 6
AREA CODE	NUMBER	EXECUTIVE OFFICER	EXECUTIVE OFFICER
			YEAR MO. DAY


TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

MONTHLY EFFLUENT REPORT

Page 2 of 3

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865



40B SYS	WQ0010543-012 PERMIT NUMBER	1 SET	0 9 YEAR	04 MO.	15651 EID
------------	--------------------------------	----------	---------------	-------------	--------------

THIS REPORT TO BE USED FOR **RECLAIMED WATER TYPE II "900"**
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS
 PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
		VALUE					
000085342 TRANSFER DAYS MON	REPORTED	30	0	01		01	
	PERMITTED			01	NA	01	NA
316164024 FEC. COLI DLY AVG	REPORTED	<3	0	11		03	
	PERMITTED	200.000		11	2/WEEK	03	GRABPKLOAD
316164030 FEC. COLI IND GRAB	REPORTED	10	0	11		03	
	PERMITTED	800.000		11	2/WEEK	03	GRABPKLOAD
500507124 FLOW DLY AVG	REPORTED	4.59	0	02		11	
	PERMITTED			02	CONT	11	CONT
800821024 BOD CARB DLY AVG	REPORTED	<2	0	11		03	
	PERMITTED	15.000		11	2/WEEK	03	GRABPKLOAD
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0011708	0	01		01	
	PERMITTED			01	NA	01	NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	12/05/12	0	01		01	
	PERMITTED			01	NA	01	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	B	0	01		01	
	PERMITTED			01	NA	01	NA
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						

COMMENTS AND EXPLANATIONS (Reference all attachments here)

Data represents reclaimed water flow from South Austin Regional WWTP TPDES Permit # 10543-012, EPA ID TX0071889

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE		NAME	SIGNATURE	DATE
		Randall Swenson	<i>Randall Swenson</i>	0 9 0 5 0 6
TELEPHONE NUMBER		PLANT OPERATOR	PLANT OPERATOR	
5 1 2	9 7 2	0 1 0 1	0 9 0 5 0 6	
NUMBER		EXECUTIVE OFFICER	EXECUTIVE OFFICER	
		Greg Meszaros, Director	0 9 0 5 0 6	
		<i>Greg Meszaros</i>	YEAR MO. DAY	


TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

P.O. BOX 13087 • CAPITOL STATION • AUSTIN, TEXAS 78711-3087

MONTHLY EFFLUENT REPORT

Page 3 of 3

AUSTIN, CITY OF
AUSTIN WATER UTILITY
P.O. BOX 1088
AUSTIN, TEXAS 78767-8865



40B SYS	WQ0010543-011 PERMIT NUMBER	1 SET	0 9 YEAR	0 4 MO.	15652 EID
------------	--------------------------------	----------	---------------	--------------	--------------

THIS REPORT TO BE USED FOR **COMBINED TYPE I AND II RECLAIMED WATER**
SEE BACK FOR INSTRUCTIONS AND DEFINITIONS
PLEASE RETAIN A PHOTOCOPY FOR YOUR RECORDS

TCEQ COPY

PARAMETER	EFFLUENT CONDITION		NO. EX.	FREQUENCY OF ANALYSIS		SAMPLE TYPE	
		VALUE					
500507124 FLOW	REPORTED	4.68	0	01		01	
DAILY AVG	PERMITTED			01	NA	01	NA
NUMBER OF OPERATOR CERTIFICATE	REPORTED	WW0018247	0	01		01	
	PERMITTED			01	NA	01	NA
EXPIRATION OF OPERATOR CERTIFICATE	REPORTED	09/11/12	0	01		01	
	PERMITTED			01	NA	01	NA
CLASS OF OPERATOR CERTIFICATE	REPORTED	A	0	01		01	
	PERMITTED			01	NA	01	NA
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						
	REPORTED						
	PERMITTED						

COMMENTS AND EXPLANATIONS (Reference all attachments here)

Reclaimed water flow from both Walnut Creek WWTP and South Austin Regional WWTP. Walnut Creek transferred reclaimed water 18 days and South Austin Regional WWTP transferred reclaimed water 28 days.

I CERTIFY THAT I AM FAMILIAR WITH THE INFORMATION CONTAINED IN THIS REPORT AND THAT TO THE BEST OF MY KNOWLEDGE AND BELIEF SUCH INFORMATION IS TRUE AND COMPLETE AND ACCURATE

NAME		SIGNATURE		DATE	
Mike Welch				0 9 0 5 0 6	
TELEPHONE NUMBER		PLANT OPERATOR		YEAR MO. DAY	
5 1 2 9 7 2 0 1 0 1		Greg Meszaros, Director		0 9 0 5 0 6	
NUMBER		EXECUTIVE OFFICER		YEAR MO. DAY	